



## BOROUGH OF ROYERSFORD

300 MAIN STREET  
ROYERSFORD, PENNSYLVANIA 19468  
(610) 948-3737 • FAX (610) 948-2915



### LIFE SAFETY INSPECTION

#### Items Inspected:

- Emergency Lighting and Illuminated Exit Signs
- Smoke Detectors and CO Detectors
- Fire Alarm System working properly (where required)
- Fire Extinguisher (charged)
- Fire escape in good condition, if existing
- KnoxBox present & keys/owner information updated
- Sprinkler System working properly (where required)
- GFCI Receptacles within 6 feet of water
- Receptacles/Switches wired properly and working
- Electrical panel accessible and all breakers labeled
- No exposed/unprotected electrical wiring
- Functioning Bathroom
- Plumbing fixtures working properly including hot water
- Mechanicals working properly and serviced with last year
- Guard rails installed where required (walking surfaces 30" above grade)
- Handrails on all stairways/elevation changes
- Exterior of property in good condition